

Message Text

CONFIDENTIAL

PAGE 01 LISBON 04588 121517Z

44

ACTION SY-05

INFO OCT-01 EUR-12 ISO-00 /018 W
----- 040104

P R 121425Z AUG 75

FM AMEMBASSY LISBON

TO SECSTATE WASHDC PRIORITY 3748

INFO AMEMBASSY BONN

AMCONSUL FRANKFURT

C O N F I D E N T I A L LISBON 4588

SECSTATE FOR A/SY/FO, BONN FOR RCO, FRANKFURT FOR RSS.

E.O. 11652: GDS

TAGS: ASEC, ACOM

SUBJ: SECURITY INSPECTION, AMCONSUL PONTA DELGADA

1. SECURITY VAULT, PONTA DELGADA, CONTAINS SAFE-FILE DOOR OF NO IDENTIFIABLE MANUFACTURE. DOOR CONTAINS S&G 8400 GROUP I LOCK WITH OPERATIVE ESCAPE DEVICE; NO OPTICAL DEVICE. BASIC CONSTRUCTION OF VAULT DOOR IS 1/8 INCH STEEL FRAME, FACED WITH 1/16 STEEL PLATE FRONT AND BACK. THICKNESS OF DOOR IS 2-1/2 INCHES OVERALL. TO SATISFY SKAG-1B, CLASS 5 OR 6 VAULT DOOR WILL BE REQUIRED.
2. THIRD FLOOR, ABOVE VAULT AREA, IS PRIVATE APARTMENT LEASED BY LOCAL TENANT WHO DESIRES TO RETAIN LEASE. EFFORT BY BUILDING LANDLORD TO OBTAIN LEASE FOR CONSULATE NEGATIVE. CONSULATE THEREFORE UNABLE TO ASSURE 13 FEET VERTICAL RADIUS CONTROLLED SPACE FROM PROPOSED EQUIPMENT.
3. CONSULATE HAS NO SATISFACTORY METHOD OF DESTROYING CLASSIFIED WASTE. PRESENT MARTIN INCINERATOR INOPERATIVE DUE TO FAULTY ENGINEERING OF FLUE WHICH ALLOWS SMOKE ESCAPE IN UPPER LEVEL PRIVATE RESIDENCES. DISINTEGRATOR, SUCH AS SEM MODEL 700, RECOMMENDED.
4. DOOR LEADING FROM PUBLIC STAIRWELL/ELEVATOR ACCESS AREA INTO SECOND-FLOOR AREA HOUSING VAULT SHOULD BE REPLACED WITH METAL DOOR, USING EXISTING YALE 197 LOCK. TO PROVIDE OPERATIONAL
CONFIDENTIAL

CONFIDENTIAL

PAGE 02 LISBON 04588 121517Z

PRIVACY AND FREEDOM FROM VISUAL OBSERVATION, PARTITION IN HALWAY

SHOULD BE CONSTRUCTED. PARTITION SHOULD BE OF COMPOSITION COMMENSURATE WITH STRENGTH OF EXISTING WALLS AND ALSO CONTAIN SOLID-CORE WOOD DOOR WITH YALE 197 OR EQUIV. TWO OTHER DOORS IN AREA REQUIRE MINOR MODIFICATION, INCLUDING INSTALL OF ADDITIONAL YALE 197 LOCK. CONSULATE REQUESTED OBTAIN COST ESTIMATES ON ITEMS THIS PARA.

5. POUCH REPORT FOLLOWS.
OKUN

CONFIDENTIAL

NNN

Message Attributes

Automatic Decaptioning: X
Capture Date: 01 JAN 1994
Channel Indicators: n/a
Current Classification: UNCLASSIFIED
Concepts: n/a
Control Number: n/a
Copy: SINGLE
Draft Date: 12 AUG 1975
Decaption Date: 01 JAN 1960
Decaption Note:
Disposition Action: RELEASED
Disposition Approved on Date:
Disposition Authority: ElyME
Disposition Case Number: n/a
Disposition Comment: 25 YEAR REVIEW
Disposition Date: 28 MAY 2004
Disposition Event:
Disposition History: n/a
Disposition Reason:
Disposition Remarks:
Document Number: 1975LISBON04588
Document Source: CORE
Document Unique ID: 00
Drafter: n/a
Enclosure: n/a
Executive Order: GS
Errors: N/A
Film Number: D750278-0364
From: LISBON
Handling Restrictions: n/a
Image Path:
ISecure: 1
Legacy Key: link1975/newtext/t19750861/aaaacbmp.tel
Line Count: 70
Locator: TEXT ON-LINE, ON MICROFILM
Office: ACTION SY
Original Classification: CONFIDENTIAL
Original Handling Restrictions: n/a
Original Previous Classification: n/a
Original Previous Handling Restrictions: n/a
Page Count: 2
Previous Channel Indicators: n/a
Previous Classification: CONFIDENTIAL
Previous Handling Restrictions: n/a
Reference: n/a
Review Action: RELEASED, APPROVED
Review Authority: ElyME
Review Comment: n/a
Review Content Flags:
Review Date: 30 MAY 2003
Review Event:
Review Exemptions: n/a
Review History: RELEASED <30 MAY 2003 by CunninFX>; APPROVED <22 OCT 2003 by ElyME>
Review Markings:

Margaret P. Grafeld
Declassified/Released
US Department of State
EO Systematic Review
06 JUL 2006

Review Media Identifier:
Review Referrals: n/a
Review Release Date: n/a
Review Release Event: n/a
Review Transfer Date:
Review Withdrawn Fields: n/a
Secure: OPEN
Status: NATIVE
Subject: SECURITY INSPECTION, AMCONSUL PONTA DELGADA
TAGS: ASEC, ACOM
To: STATE
Type: TE
Markings: Margaret P. Grafeld Declassified/Released US Department of State EO Systematic Review 06 JUL 2006